

New Indian Environmental Norms:  
How advanced DeSO<sub>x</sub> solutions guarantee a sustainable power generation



**Dr. Annette Ziemann-Noethe**  
**Dipl.-Ing. Frank Oberheid**  
**Dipl.-Ing. Christian Demling**

**Doosan Lentjes**

## Table of Contents

- **New Indian Environmental Norms**
- **Solutions for Desulphurization Processes**
- **Requirements of the Indian Market**
- **Unique Features of the Different Technologies**
  - **Tailor-made solutions for the different processes:**
    - **Wet Lime / Limestone FGD**
    - **Circoclean® FGD / FGC**
    - **Seawater FGD**




**Case Study:**  
**Gheco One, Thailand**  
**Contract award: 2009**  
**Project:**  
Delivery of key  
SW FGD technology  
Main fuels: Coal  
Plant output: 1 x 700 MW<sub>e</sub>  
Flue gas flow (wet):  
2,158,000 Nm<sup>3</sup>/h



# Emission Norm India for Thermal Projects installed

	before 31 <sup>st</sup> Dec.2003	between 1 <sup>st</sup> Jan. 2004 – 31 <sup>st</sup> Dec. 2016	from 1 <sup>st</sup> Jan. 2017
<b>SO<sub>2</sub></b>	< 500 MW: 600 mg/Nm <sup>3</sup> > 500 MW: 200 mg/Nm <sup>3</sup>	< 500 MW: 600 mg/Nm <sup>3</sup> > 500 MW: 200 mg/Nm <sup>3</sup>	100 mg/Nm <sup>3</sup>
<b>NO<sub>x</sub></b>	600 mg/Nm <sup>3</sup>	300 mg/Nm <sup>3</sup>	100 mg/Nm <sup>3</sup>
<b>PM<sup>2.5</sup></b>	100 mg/Nm <sup>3</sup>	50 mg/Nm <sup>3</sup>	30 mg/Nm <sup>3</sup>
<b>Hg</b>	> 500 MW 0.03 mg/Nm <sup>3</sup>	0.03 mg/Nm <sup>3</sup>	0.03 mg/Nm <sup>3</sup>



## Solutions for Desulphurization Processes: Doosan Lentjes' APC Products –

### ■ Wet Lime / Limestone FGD

- 205 absorbers installed (110 absorbers in China) (DHI: additional 19 absorbers, 10.7 GW<sub>e</sub> installed)
- 71 GW<sub>e</sub> total capacity
- Maximum absorber size: 1,000 MW<sub>e</sub>

### ■ Seawater FGD

- 14 absorbers installed (7 absorbers in cooperation with DHI)
- 8 GW<sub>e</sub> total capacity
- Maximum absorber size: 700 MW<sub>e</sub>

### ■ Circoclean® FGD / FGC

- 88 reactors installed (18 reactors in China, 26 in the USA, 2 in cooperation with DHI)
- 13 GW<sub>e</sub> total capacity
- Maximum reactor size: 305 MW<sub>e</sub>



### Case Study: Rugeley, United Kingdom

Contract award: 2006  
Project: Flue gas  
desulphurisation plant  
retrofit  
Main fuel: Coal  
Plant output: 1 x 500 MW<sub>e</sub>  
Max. flue gas flow rate  
(wet): 2,103,000 Nm<sup>3</sup>/h

# Our Products and Services

## Boiler Business Group

**Lentjes  
Business Unit**



**Boiler Business  
Unit**



**Babcock  
Business Unit**



**Future Energy  
Business Unit**



**Doosan Lentjes is the global  
center of competence  
for CFB, WtE and APC in DHI and has its own  
R&D center for these technologies**

# Our Product Lines — CFB, WtE and APC



Tisova, 100MW<sub>e</sub>  
Czech Republic

**CFB**  
Circulating  
Fluidised  
Bed

- *Top tier level CFB OEM technology*
- *References: 113 units (22 GW<sub>th</sub>, max. 280 MW<sub>e</sub>)*



REC Harlingen, NL  
280,000 t/a; 1 line

**WtE**  
Waste-to-Energy

- *Top tier WtE OEM technology*
- *References: 77 units (9 mill t/a, max. 35 t/h)*
- *Chute-to-stack or full turnkey supply solutions*



Oroszlany, Hungary  
240MW<sub>e</sub>, Wet Stack

**APC**  
Air  
Pollution  
Control

- *Various APC OEM technologies*
- *References:*
  - *Wet FGD: 205 units (71 GW<sub>e</sub>, max. 1,000 MW<sub>e</sub>)*
  - *Seawater FGD: 14 units (8 GW<sub>e</sub>, max. 700 MW<sub>e</sub>)*
  - *Circoclean® FGD / FGC: 88 units (13 GW<sub>e</sub>, max. 305 MW<sub>e</sub>)*
  - *SCR DeNO<sub>x</sub>*
  - *Fabric Filters and ESP*

**Today's Focus**


## FGD Technology – Origin




## Comparison of FGD processes

Description	Unit	Circoclean® FGD/ FGC	Seawater FGD	Wet Limestone FGD
Suitable for high sulphur	mg/Nm <sup>3</sup>	Not economic	Only with additional additives or fresh seawater	yes
SO <sub>2</sub> removal efficiency	%	>99	>99	>99
SO <sub>3</sub> removal efficiency	%	>99	approx. 50%	approx. 50%
Absorbents	-	lime	seawater	limestone/lime
Investment cost	%	70-80	70-80	100
Power consumption	% in PP capacity	1-1.5	0.8-1.5	1-2
Maintenance	%	80	30	100
Absorbents costs	%	200	0	100
By- product	-	dry calcium sulfite/ calcium sulfate mixture	sulfate ions (dissolved in seawater)	gypsum
By- product costs	-	high disposal costs	none	saleable (low price)

# Basic Flow Sheet



## Modules



## Why to prefer our proven Wet Limestone FGD technology?

- **New-build and retrofit**
- **Size: up to 1,000 MW<sub>e</sub> and even more**
- **Application for a wide range of fuels: coal, lignite, heavy fuel oil**
- **Suitable for:**
  - **High sulphur applications**
  - **Large scale power plants**




### **Case Study: Taichung, Taiwan**

**Contract award: 1993**  
**Project: Provision of a limestone FGD plant on a turnkey basis**  
**Main fuel: Coal**  
**Plant output (unit 1-4): 4 x 550 MW<sub>e</sub>**  
**Max. flue gas flow: 2,150,000 Nm<sup>3</sup>/h**



## Overall Reactions



## Requirements of the Indian Market

Requirements	
▶	Reliable and proven FGD technology ensured by reference plants
▶	Optimized design regarding Capex and Opex
▶	Minimized water consumption, limited waste water
▶	Small and optimized plant footprint especially for retrofit projects
▶	Short erection period, short shut down periods
▶	Regarding retrofit projects: relining of chimney and installation of booster fan

## Key Project Data Rugeley

<b>Customer</b>	International Power plc
<b>Location of power station</b>	Rugeley, Staffordshire, UK
<b>Award date</b>	2006
<b>Gross power generation (per unit)</b>	500 MW <sub>e</sub>
<b>Number of units</b>	2
<b>Maximum flue gas flow rate (wet)</b>	2,103,000 m <sup>3</sup> /h (STP)
<b>Maximum S content in coal</b>	1%
<b>Maximum SO<sub>2</sub> inlet concentration</b>	2,076 mg/m <sup>3</sup>
<b>Guaranteed emissions (acc 6% O<sub>2</sub>, dry)</b>	
So <sub>2</sub> removal efficiency	94%
Particulate matter	25 mg/m <sup>3</sup> (STP)
Waste water	10.5 m <sup>3</sup> /h



EEC 2016: DeSOx Technologies to meet new Indian Environmental Norms – DL Reference Plant in Rugeley




Virtual Tour - Pano 6 Panorama




## Precise and Accurate Design Calculation: Doosan Lentjes Software Tool

	<b>Consideration of all chemical and physical processes and interactions</b>
▶	Validated by all performance data documented in the extensive database for all Doosan Lentjes reference plants
▶	Precise calculation of plant dimensions regarding correlation of Capex and Opex
▶	Consideration of all key design parameters: <ul style="list-style-type: none"><li>• Limestone reactivity</li><li>• Limestone particle size distribution</li><li>• Organic acid dosage</li><li>• Position of spray level in operation</li><li>• Absorber height</li><li>• Temperature of suspension</li><li>• Chloride concentration</li><li>• Absorbent droplet size</li><li>• Effect of SO<sub>2</sub> and CO<sub>2</sub> concentration on mass transfer</li><li>• ...</li></ul>

## Optimized Design regarding Capex and Opex



## Optimized Design regarding Capex and Opex



### Reduction of L

→ Reduction of Opex

### Reduction of H

→ Reduction of Capex

### Optimal design range:

Integral consideration of L and H

→ Reduction total lifetime costs

## Minimized Water Consumption

▶	Minimizing of water evaporation by installing highly efficient gas gas heater and minimizing raw gas temperature before absorber
▶	Use of cooling water (SW) as process water
▶	FGD plant operation with no waste water by injection of residual water before ESP
▶	Installation of a waste water evaporator – highly expensive
▶	For power plants located in coastal areas the installation of SW FGD plants, where no additive or fresh water is used, has advantages.
▶	For FGD plants with a capacity of up to 350 MW <sub>e</sub> the installation of the dry Circolclean <sup>®</sup> FGD plants has a lower water consumption

## Use of Cooling Water (SW) as Process Water

### Challenges by use of seawater as process water

Commercial grade gypsum is produced in all plants.

The chlorine content in the absorber is higher than in the case of using fresh water: 40,000 ppm instead of 20,000 ppm.

Wearing of balls for the wet ball mill is higher.

Amount of bleed waste water is higher.

Chlorine content has a negative impact on removal efficiency (higher L/G to reach the same removal efficiency means higher power consumption).

For saturation of oxidation air and for gypsum washing material selection (absorber, mill, process water system) has to be suitable for the high chlorine content.

Desalinated water is required for gypsum washing. (range: 2-5% of total water consumption)




**I. Doosan Lentjes  
WLST-FGD plant in  
Rostock (510 MW<sub>e</sub>)  
with seawater used as  
process water.**

**II. Power Station Almeria,  
550 MWe, Spain,  
Mediterranean Sea**

**III. Power Station  
Iskenderun, 2 x 606  
MWe, Turkey,  
Mediterranean Sea**





## Spray Tower Design



- Mist Eliminators
- Spraying Zone
- Sump equipped with Impulse Suspending System

## Sump Design



## Special advantages only available with Doosan Lentjes' Sump System

- Suspends the solids without moving parts within the absorber
- Two different zones for oxidation and crystallization
- Better utilization of consumables
- Higher quality of gypsum
- Trouble-free restart of IS-system after FGD shut-down
- No need to operate Impulse Suspension System during shut-down

## Aspects Regarding the Choice of Fan for Wet FGD Systems

### ■ Combined ID Fan

- State of the art solution for new-build power plants
- References available
- Simpler control loop for flue gas flow
- Reduced danger of flue gas pressure oscillation, smooth operation
- Investment cost saving

### ■ Booster Fan dedicated to FGD


- Preferred for retrofit projects
- No adaption of existing ID fan means reduced tie-in period
- Better efficiency during bypass-operation



## Aspects Regarding the Choice of Type of Chimney

### ■ Chimney Design and Material Selection

- Common stand-alone chimney with one or more flues possible
- Wet stack may also be built on top of absorber
- Existing chimney may be used as FGD by-pass
- In case existing chimney will be modified and reused, stand-still period has to be considered
- Material selection for flue:
  - Carbon steel with flake lining
  - Carbon steel with rubber lining
  - FRP
  - Acid resistant bricks
  - Alloy material



## Customer Benefits

- A simple solution to remove SO<sub>2</sub>, HCl and HF
- SO<sub>2</sub> removal efficiency up to 99%
- Almost stoichiometric absorbent consumption
- Spray tower absorber not susceptible to clogging due to patented Impulse Suspension System
- Individual spray levels can be switched off during low load or low sulphur fuel operation to reduce power consumption
- Variety of corrosion resistant materials available for absorber design
- A high-quality gypsum is created as a by-product which has manifold uses




### Case Study: Dolna Odra, Poland

Contract award: 1999  
Project: Provision of a  
flue gas cleaning plant  
for boilers 7+8  
Main fuel: Coal  
Plant output: 1 x 220  
MW<sub>e</sub>  
Max. flue gas flow  
(wet): 1,926,000 Nm<sup>3</sup>/h

**Doosan Lentjes**

## Doosan Lentjes' Capabilities at a Glance

- More than 40 years of experience with FGD technology
- Three different FGD technologies available
- Worldwide proven technology is own IP of Doosan Lentjes
- High number of references for all FGD technologies
- Experience with seawater as process water (WLST FGD)
- Continuous intensive R&D in own laboratory
- In-house CFB modelling



## Wet Lime / Limestone FGD Plant References

Location Fiddler's Ferry, UK  
Customer Scottish and Southern Energy  
Capacity 3 x 500 MW<sub>e</sub>  
Fuel Hard coal

Location Ferrybridge, UK  
Customer Scottish and Southern Energy  
Capacity 2 x 500 MW<sub>e</sub>  
Fuel Hard coal

Location Rugeley, UK  
Customer International Power plc  
Capacity 2 x 500 MW<sub>e</sub>  
Fuel Hard coal




## Wet Lime / Limestone FGD Plant References

Location	Oroszlány, Hungary
Customer	Vertes Power Plant Limited
Capacity	1 x 240 MW <sub>e</sub>
Fuel	Lignite
Location	Lippendorf, Germany
Customer	Vattenfall / EnBW
Capacity	2 x 933 MW <sub>e</sub> , 4 absorbers
Fuel	Lignite
Location	Cayirhan, Turkey
Customer	TEAS
Capacity	2 x 150 MW <sub>e</sub>
Fuel	Lignite (extreme high sulphur)




# Circoclean® FGD – Basic Flow Sheet



## Why to prefer our proven Circoclean® technology?


- New-build and retrofit
- Power stations and waste-to-energy plants
- Size: up to 350 MW<sub>e</sub> and even more
- Wide range of fuels: coal, lignite, heavy fuel oil, municipal and industrial waste
- SO<sub>2</sub>, SO<sub>3</sub>, HCl, HF removal efficiency up to 99% and more
- Usage of hydrated lime as additive
- Hydration of burnt lime on site possible
- Usage of limestone in fuel, calcined in upstream CFB boiler
- Removal of PCDD, PCDF and heavy metals with optional activated carbon injection



**Case Study:**  
**Cochrane, Chile**  
Contract award: 2014  
Project: Engineering, manufacture and supply of dry FGD system  
Main fuel: Hard coal  
Plant output: 2 x 250 MW<sub>e</sub>  
Flue gas flow (wet): 2 x 857,000 Nm<sup>3</sup>/h  
**Doosan Lentjes**

## Overall Reactions

Main reactions, significant for the flue gas desulphurisation in the fluidised bed



Additional reactions with chlorides and fluorides



In case of usage of activated carbon adsorption of:  
**PCDD, PCDF and Heavy Metals**

Parallel reaction with CO<sub>2</sub>, forming limestone



## Circoclean® FGD / FGC Plant Design



- Circoclean® Reactor (1)
- Filter (2)
- Venturi Nozzle (3)

## Multiple Venturi Nozzle (Flow > 400,000 Nm<sup>3</sup>/h)

**Inlet View**



**Outlet View**

## Customer Benefits

- Moderate process water consumption
- Small power consumption
- Small foot print
- No waste water – dry particles only
- High SO<sub>3</sub> removal
- No flue gas re-heating
- Reactor made of carbon steel
- Easy adoption to higher SO<sub>x</sub> removal
- Attractive investment costs




### Case Study: Iași, Romania

Contract award: 2014  
Project: Delivery of  
key Circoclean® FGD  
technology Main fuel:  
Lignite Plant output:  
1 x 50 MW<sub>e</sub>


Flue gas flow (wet):  
623,500 Nm<sup>3</sup>/h

## Low Pressure Pulse Jet Fabric Filter downstream Circoclean® FGD / FGC Reactor




### Customer Benefits

- Far less than 10 mg/m<sup>3</sup>
- Independent from boiler load
- DeSO<sub>x</sub> – effect in ash layer on filter bag
- Furnace sorption injection or CFB installation possible
- Relatively low investment costs
- Higher life time of filter bags



# Typical Layout



- Product Silo (1)
- Sorbent (Lime) Silo (2)
- Absorber (3)
- Fabric Filter (4)
- Absorber Inlet (5)
- Electrical Building (6)

## Key Project Data Cochrane

<b>Customer</b>	AES/ Empresa Eléctrica Cochrane (EEC)
<b>Location of power plant</b>	Mejillones, Chile
<b>Award date</b>	2014
<b>Main fuels</b>	hard coal
<b>Gross power generation</b>	2 x 250 MW <sub>e</sub>
<b>Flue gas flow rate</b>	2 x 857,000 m <sup>3</sup> / h (STP, wet)
<b>DeSO<sub>x</sub> - technology</b>	Circoclean® FGD
Number of lines	2
<b>SO<sub>2</sub> inlet concentration</b>	1865 mg/ Nm <sup>3</sup> dry @ 6% O <sub>2</sub>
<b>Dust inlet concentration</b>	21,100 mg/ Nm <sup>3</sup> dry @ 6% O <sub>2</sub>
<b>Guaranteed emissions</b>	
SO <sub>2</sub>	200 mg/ Nm <sup>3</sup> dry @ 6% O <sub>2</sub>
SO <sub>2</sub> removal efficiency	88.6%
Dust	30 g/ Nm <sup>3</sup> dry @ 6% O <sub>2</sub>
Dust removal efficiency	99.85%




## Circoclean® FGD Plant References

Location Moneypoint, Ireland  
Customer Electricity Supply Board (ESB)  
Capacity 3 x 305 MW<sub>e</sub>  
Fuel Hard coal

Location Plzen, Czech Republic  
Customer Plzeňská Teplárenská a.s.  
Capacity 3 x 35 Mw<sub>e</sub> – 1 reactor  
Fuel Lignite

Location Usti nad Labem, Czech Republic  
Customer SETUZA Cinergetika U/L, a.s.  
Capacity 1 x 65 MW<sub>e</sub>  
Fuel Lignite



## Circoclean® FGC Plant References

Location Antwerp, Belgium  
Customer Indaver N.V.  
Capacity 3 x 105,000 Nm<sup>3</sup> / h  
Fuel Municipal and industrial waste


Location Allington  
Customer Kent Enviropower  
Capacity 3 x 100,000 Nm<sup>3</sup> / h  
Fuel Municipal waste

Location Frankfurt am Main, Germany  
Customer AVA Nordweststadt  
Capacity 4 x 114,000 Nm<sup>3</sup> / h  
Fuel Municipal waste



# SWFGD - Background

## Typical Flow Sheet – Example: Open Spray Tower






Virtual Tour - 4b\_Blick auf Absorber

## Types of SWFGD Absorbers

### ■ Influencing factors on product selection

- SO<sub>2</sub> raw gas content
- Required SO<sub>2</sub> removal efficiency
- Seawater quality , e.g.:
- Temperature
- pH value
- Alkalinity
  
- **Focus on:**
- Capex
- Opex
- Hybrid solution



# Field Study at Gheco One Power Plant

## Validation at full size Power Plants

### Verification of models and experimental results




Gheco One, Thailand  
1 x 660 MW<sub>e</sub>, coal

**Absorber Type:**  
Open Spray Tower

**No. of spray levels:** 4  
**No. of oxidation air blowers:** 2+1 standby




**Maximum SO<sub>2</sub> concentration (Raw Gas):**  
~2700 mg/Nm<sup>3</sup>



- SO<sub>2</sub> removal in absorber
- Flue gas grid measurements under different operating conditions

### pH increase and oxidation in aeration basin

- Seawater measurements under different operating conditions
- Flow optimization
- Pressure drop measurements under different operating conditions





Virtual Tour - 4b\_Blick auf Absorber



# Field Study at Gheco One Power Plant

## Flue Gas Grid Measurements

### Measuring grids



- Raw gas upstream GGH (25 measuring points)
- Clean gas upstream GGH (24 measuring points)
- Clean gas downstream GGH (20 measuring points)

### Measured values

- SO<sub>2</sub>-concentration
- O<sub>2</sub>-concentration
- CO<sub>2</sub>-concentration
- H<sub>2</sub>O-concentration
- Flue gas temperature
- Static pressure
- Flue gas velocity

### A different number of spray pumps (4, 3, 2) were in operation

- 6 test runs were executed



Doosan Lentjes




# Field Study at Gheco One Power Plant

## Flue Gas Grid Measurements

### ■ Results (selected data)


- Coal with less sulphur content than planned is fired
- SO<sub>2</sub> removal efficiency of  $\geq 99\%$  can be reached
- SO<sub>2</sub> removal efficiency between  $\geq 93.5\%$  and  $\geq 99\%$  were measured depending on number of operated spray banks and height of operated spray bank
- The emission limits were upheld under all operating conditions
- Homogeneous distribution of SO<sub>2</sub> at stack
- Result of flow optimization
- The expected calculated values were reached
- Validation of experimental and modelled results successful
- New operation concept
- Customer benefits: Reduction of power consumption under current operating conditions



## Field Study at Gheco One Power Plant

### Seawater Measurements




- Measurements in aeration basin in parallel to flue gas grid measurements
- Measured values at 12 measuring points (selected values)
  - pH Value
  - Alkalinity
  - Dissolved Oxygen [DO]
  - $\text{SO}_3^{2-}$  concentration
    - Chemical Oxygen Demand [COD] increase
  - Salinity
    - Conductivity
  - Temperature
  - Seawater Velocity
- Different number of oxidation air blowers (1, 2) were in operation
  - Influence on performance of aeration
- Different number of absorber spray pumps (2,3,4) were in operation
  - Influence on seawater inlet quality to aeration basin
- 12 test runs



# Field Study at Gheco One Power Plant Seawater Measurements

## Results (selected data)

- Correlation between pH value and SO<sub>2</sub> removal efficiency (basin Inlet pH value)
- Higher SO<sub>2</sub> removal efficiency → Lower aeration basin inlet pH value
- All emission limits are kept under all operating conditions
- pH-value and DO increase faster, when more air is brought into aeration system
- The expected calculated values were reached
- Validation of experimental and modelled results successful
- New operation concept
- Customer benefits: Reduction of power consumption under current operating conditions



## Why to prefer proven SWFGD technology?


- **Cost effective solution for plants in coastal regions:**
  - Seawater is used as an absorbent
  - Seawater typically taken from the power plants cooling circuit
- **Size: up to 1,000 MW<sub>e</sub> and higher**
- **Application for a wide range of different fuels:**
  - coal
  - lignite
  - heavy fuel oil
- **Applicable for a wide range of SO<sub>2</sub> raw gas concentrations**
- **High level of removal efficiency, ≥ 99% possible**
- **No by-product and no additional absorbents necessary**
- **Low operating and capital costs**



**Doosan Lentjes**

## SWFGD Plant References

Location	Vinh Tan
Customer	Vietnam National Coal – Mineral Industries Holding Corp. Ltd.
Capacity	2 x 620 MW <sub>e</sub>
Fuel	Hard coal
Location	Rabigh, KSA
Customer	Doosan Heavy Industries & Construction
Capacity	4 x 700 MW <sub>e</sub>
Fuel	HFO
Location	Gheco One, Thailand
Customer	Doosan Heavy Industries & Construction
Capacity	1 x 700 MW <sub>e</sub>
Fuel	Hard coal





## SWFGD Plant References

Location Qatalum, Qatar  
Customer SNC Lavalin  
Capacity 4 units  
Fuel Aluminium smelter gas

Location Madinat Yanbu, KSA  
Customer Enel Power  
Capacity 1 x 130 MW<sub>e</sub>  
Fuel HFO

Location Paiton, Indonesia  
Customer Siemens  
Capacity 2 x 660 MW<sub>e</sub>  
Fuel Hard coal



# Questions?



**Annette Ziemann-Nöthe**

Dr. rer. nat.  
Product Manager  
WLST/Seawater FGD

**Doosan Lentjes GmbH**

Daniel-Goldbach-Str. 19  
40880 Ratingen, Germany  
T +49 (0) 2102 166 1492  
F +49 (0) 2102 166 2492

[www.doosanlentjes.com](http://www.doosanlentjes.com)

[annette.ziemann-noethe@doosan.com](mailto:annette.ziemann-noethe@doosan.com)

# Thank you धन्यवाद ! Danke



**Doosan Lentjes**

## Backup

- Save flue gas desulphurization processes reduce SO<sub>2</sub> emissions to a minimum according to new Indian environmental norms
- Provision of complete clean gas packages from boiler to stack (SO<sub>x</sub>, NO<sub>x</sub>, PM, Hg)
- Clean and efficient power generation from coal and biomass support a sustainable long-term growth of the Indian economy
- Reliable waste-to-energy solutions help India reduce its waste volumes (>90%) while recovering valuable energy



**Indian's Powerful German Engineering and Technology Partner - for Protection of the Environment**

