

Flexible Power for integration of renewable generation

Solar & Wind capacity (GW)

| | As on September, 2019 | Expected in Year, 2021-22 |
|--------------|--------------------------|------------------------------|
| Solar | 31.10 | 100 |
| Wind | 36.93 | 60 |
| Biomass | 9.95 | 10 |
| Small hydro | 4.61 | 5 |
| Total | 82.59 | 175 |

Statewise renewable capacity (MW) in year,2021-22

| State/UTs | Solar Power (MW) | Wind (MW) | SHP (MW) | Biomass | Total |
|-----------------------|------------------|-----------|----------|---------|-------|
| Maharashtra | 11926 | 7600 | 50 | 2469 | 22045 |
| Tamil Nadu | 8884 | 11900 | 75 | 649 | 21508 |
| Andhra Pradesh | 9834 | 8100 | | 543 | 18477 |
| Gujarat | 8020 | 8800 | 25 | 288 | 17133 |
| Karnataka | 5697 | 6200 | 1500 | 1420 | 14817 |
| Rajasthan | 5762 | 8600 | | | 14362 |
| Uttar Pradesh | 10697 | | 25 | 3499 | 14221 |
| Madhya Pradesh | 5675 | 6200 | 25 | 118 | 12018 |
| West Bengal | 5336 | | 50 | | 5386 |
| Punjab | 4772 | | 50 | 244 | 5066 |
| Haryana | 4142 | | 25 | 209 | 4376 |

Installed capacity


| | As on 30.09.2019 | | As on 31.03.2022 | | As on 31.03.2030 | |
|------------|------------------|--------|------------------|--------|------------------|--------|
| | (GW) | (%) | (GW) | (%) | (GW) | (%) |
| Thermal: | 203.0 | 56.00 | 217.0 | 45.30 | 266.8 | 32.1 |
| Hydro: | 45.0 | 12.45 | 51.0 | 10.65 | 73.4 | 8.8 |
| Gas: | 25.0 | 6.90 | 26.0 | 5.43 | 25.0 | 3.0 |
| Nuclear: | 6.8 | 1.87 | 10.0 | 2.09 | 16.8 | 2.0 |
| Renewable: | 82.5 | 22.78 | 175.0 | 36.53 | 450.0 | 54.1 |
| Total: | 362.30 | 100.00 | 479.00 | 100.00 | 832.00 | 100.00 |

Demand & Generation Analysis


Year,2021-22



Hourly Generation prediction, year,2021-22

1. **Solar, Wind, Nuclear & Hydro**: The generation of Solar, Wind, Nuclear & Hydro are predicted on the basis of their past generation trend and the capacity considered in the year 2021-22.
 2. **Gas**: The gas generation data has been taken from CEA.
 3. **Small Hydro, Biomass**: Since no reliable data is available for these small renewable sources, straight line assumptions has been used. Small Hydro is taken as 1000 MW and Biomass as 2000 MW as constant values.
 4. **Demand**: The national electricity demand for the year 2021-22 has been collected from 19th EPS, CEA
 5. **Coal**: It is calculated figure. Added hourly generation of all generation sources except coal and subtracted from hourly demand and the result is the required hourly generation from coal.
- 

Demand & Generation on the day 27th July, 2021




- Total Load (2021-22)
- Nuclear BAU
- Small Hydro BAU
- Biomass BAU
- Gas BAU
- Hydro BAU
- RES (S+W) BAU
- Coal BAU

MTL on significant days

| S.No. | Day | Date | Max Total Demand | Max RES Generation | MTL | Max. Ramp Rate (MW/min) |
|-------|-----------------------|------------------------------|------------------|--------------------|--------|-------------------------|
| 1 | Highest Demand Day | 7 th October 2021 | 225751 | 52421 | 62.65% | -216 |
| 2 | Lowest Demand Day | 13 th March 2022 | 185585 | 74684.5 | 48.21% | -422 |
| 3 | Highest RE Day | 1 st July 2021 | 201723 | 108926 | 33.39% | -332 |
| 4 | Highest Ramp Down Day | 13 th March 2022 | 185585 | 74684 | 48.21% | -422 |
| 5 | Highest Ramp Up Day | 3 rd Feb 2022 | 200364 | 74701 | 53.02% | 379 |
| 6 | Lowest MTL Day | 27 th July 2021 | 190480 | 108082 | 25.73% | -310 |

Ramp Rate - Requirement

27th July 2021



Ramp Rate:
-310 MW/min. at 900 hrs.
+305 MW/min. at 1600 hrs.

Ex-bus generation of TPP: 117 GW
139 GW thermal capacity on Bar
Ramp capability: 1390 MW/min


The highest ramp down: - 422 MW/min. 13th Mar,2022
Ex-bus generation of TPP: 140 GW,
Thermal capacity to be synchronized: 167 GW.
Ramp capability: 1670 MW/min.

The highest ramp up: 379 MW/min. 3rd Feb,2022
Ex-bus generation of TPP: 154 GW,
Thermal capacity to be synchronized: 184 GW.
Ramp capability: 1840 MW/min.

Renewal generation integration into grid



| | | |
|---------------------------------|---|------------------------------|
| Most critical day | : | 27 th July,2021 |
| Renewable gen. | : | 108 GW |
| Peak thermal ex-bus/ gross gen. | : | 116.7 GW / 139.5 GW |
| Min. thermal ex-bus/gross gen. | : | 32.6 GW / 35.9 GW |
| Average MTL | : | 25.7% |
| Flexible power required | : | 39 GW (considering 55% MTL) |

Coordinated Effort


- Step I: Hydro & Gas Reallocation
 - Step II: Two Shift Operation of Thermal units+ Pump/ Battery Storage
- 

Step 1: Hydro, PS Flexing & Gas Flexing

- Additional **6200 MW hydro gen. flexing** including **4785 MW running & 1205 MW of under construction PS.**
- Regulatory intervention is proposed for:
 - **Lucrative tariff /incentives**
 - **Revision of grid code,**
 - **Implementation of 2-part tariff**





Gas plants do not flex much as of today, we need **3000 MW generation flexibility** from Gas plant by start/stop




Step 2: Two shift Operation of thermal units & Battery/PS

a) Two shift Operation of thermal units




Peak thermal: Ex-bus 98 GW
capacity on bar: 117 GW

b) Battery/PS



Step III: Demand side Management

The bottom of the slide features a decorative graphic consisting of several overlapping, wavy lines in shades of light green, yellow, and orange, creating a sense of movement and flow.

Demand Side Management

Demand-Side Management (DSM) refers to initiatives that help end-users to optimize their energy use. With DSM, consumers can reduce their electricity costs by adjusting their time and quantity of use. Following measures are expected to contribute in improving the flexible power scenario from the demand side.

1. Time of Day Tariff,
2. Open Electricity Market,
3. Demand response from High Voltage industrial consumers,
4. Supply of electricity to agriculture sector by dedicated feeders,
 - Agricultural consumption = 173185 MU
 - Agricultural consumption = 17.30 %
 - Connected load = 108834529 kW
 - Nos. of consumers = 20918824

2000 MW load is shifted from night hours to peak solar gen. hour it will improve **2% MTL**.
5. Charging of Electric vehicle when solar generation is available – this will also improve MTL.


Balancing of Grid

- The installed capacity of renewables may vary from one state to another state.
- The State like Maharashtra, Tamil Nadu, Andhra Pradesh, Gujrat, Karnataka, Rajasthan, have huge capacity of renewable and they need large amount of flexible power.
- On the other hand, many states have small capacity of renewables and practically they need small amount of flexible power.
- Thus, the requirement of additional flexible power of RE rich states can easily be met from surplus flexible power available in other states.
- Thus, curtailment of renewable generation can be avoided in RE rich state if their system balancing is done with the support from other states.

Identification of thermal units for flexible operation



1. Increase in tariff due to increase in Net Heat Rate



2. Life Consumption reflected in increased O&M cost

| MW | Event | O&M Cost (INR-Lakh) | | | % Addl. / event |
|-----|----------------------------|---------------------|--------|--|-----------------|
| | | Per Event | Per MW | Per MW (Current level) As allowed by CERC 2017 | |
| 200 | Cold Start | 91.3 | 0.46 | 28.70 | 1.59% |
| | Warm Start | 51.4 | 0.26 | | 0.90% |
| | Hot Start | 38.0 | 0.19 | | 0.66% |
| | Significant load following | 0.5 | 0.01 | | 0.01% |
| 500 | Cold Start | 262.2 | 0.52 | 19.22 | 2.73% |
| | Warm Start | 151.6 | 0.30 | | 1.58% |
| | Hot Start | 123.0 | 0.25 | | 1.28% |
| | Significant load following | 2.7 | 0.01 | | 0.03% |

Pilot test

The bottom of the slide features a decorative graphic consisting of several overlapping, wavy lines in shades of light green, yellow, and orange, creating a sense of motion and depth.

Test/study conducted

1. Dadri, 500 MW unit# 6, NTPC
2. Mouda, 500 MW unit# 2, NTPC
3. Sagardighi, 500 MW unit# 3 , WBPDC
4. Vindhyachal, 500 MW unit# 11, NTPC
5. Anpara B, 500 MW unit# 4 & 5, UPRVNL

Measures Identified

- Thermo-Mechanical Assessment
- Condition Monitoring
- Fine tuning of Existing CMC Logic
- Steam temperature Controls
- Flue Gas Temperature Controls
- Fuel firing system optimization
- Automatic startup & shutdown of Mills
- BFP Operation at Low Load
- Primary Frequency Control
- Turbine Blade Vibration Monitoring

Regulatory intervention

1. Capex: Implementation of measures for flexible operation

Capex: actual basis after examination

1. Opex:


- Increase in Net Heat Rate at low load
- Life Consumption reflected in increased O&M cost

Opex: benchmarked costs (compensation) + markup (incentivisation)

Conclusion

1. Balancing shall be done at national level which will reduce the total required balancing power.
2. Hydro power plants are especially suitable for quick supply of flexible generation. Coordination with state owned hydro plants would play an important role in re-allocation of hydro generation. Pumped storage, existing and under construction, shall be used exclusively for peaking or balancing of system. To make the peak hour's generation lucrative provision of two-part tariff and revision of grid code are suggested. Regulatory intervention is required.
3. Gas power plants have better start stop capability.
4. Establishment of pump or battery storage or combination of both at strategic locations may be explored for energy storage during high solar generation period and utilizing the same during peak demand hours or at the time of need.
5. 210 MW & 500 MW units shall be operated at lower MTL than bigger size unit.
6. Among the fleet of 200 MW, 500/600 MW or 660/800 MW thermal units, which are efficient and have low ECR, should be given preference over other units in terms of generation schedule.
7. Pilot study of thermal units for operation at low load shall be conducted before implementation of measures for flexible operation as the measures are plant specific.
8. Several measures need to be undertaken to make the plants capable of low load operation, (i) Capex to be reimbursed on actual basis after examination, (ii) Opex -based on a benchmarked costs (compensation) + markup (incentivisation). Regulatory intervention is required
9. Capacity building of coal fired power plant operators becomes an important measure in the changing operational regime.
10. Demand side management including measure targeted at domestic, agricultural, industrial and e-mobility sector would enable more rational consumption pattern of electricity.

Thank You



A Scheduling Case Study

Scheduling in flexible regime with all India Merit Order Dispatch based on ECR

Factors considered for selection of a thermal unit:

1. Unit heat rate
2. Load centre unit
3. Pit head unit
4. Old units
5. New units
6. Merit Order/ ECR
7. Super critical/ Sub-critical
8. Size of unit

Categorization of units

| Symb ol | Category | Capacity Range | Capacity | No. of units |
|---------|----------------------|----------------|----------|--------------|
| X | Base Load | 660 to 800 MW | 68160 | 98 |
| Y | Flexible | 490 to 600 MW | 70770 | 133 |
| Z | Very Flexible | 195 to 360 MW | 67640 | 285 |
| TSO | Two shift operati on | < 151 MW | 10564 | 110 |
| | Total | | 217134 | 626 |

27th July with Step 1 & 2

| | 2 | 3 | 4 | | 6 |
|-----------------|---|--------------|---|---------------------------|---------------------------|
| Category | Evening Load on each category based on MOD (MW) | No. of units | Average MTL of each category as a whole | ECR range of the category | MTL range of the category |
| x | 52380 | 75 | 50.00% | 0.84 to 2.38 | 45% to 55% |
| y | 41890 | 78 | 44.00% | 1.20 to 2.36 | 40% to 50% |
| z | 23280 | 90 | 40.00% | 1.10 to 2.30 | 35% to 45% |
| Total | 117550 | 243 | 45.88% | 0.84 to 2.38 | 45.88% |

Units having higher ECR are proposed to run at lower loads than units having lower ECR within the same category.