



## International Experiences in Conceptual Designing and Operation of Water Treatment Plants

Matthias Schneider / STEAG Energy Services GmbH  
Kolkata, Raipur, Hyderabad - November 2016

**steag**

# General Remarks

- EPC Projects (Turn-Key)
- EPC supplier's choice only driven by commercial (lowest investment costs)
- No influence of owner on sup-suppliers choice
- Consultant's comments often neglected
- EPC contractor without owner's control during design, manufacturing and installation

# Basic Considerations

Which raw water quality(ies) is(are) available?

Which amount of raw water is available?

Which water qualities must be reached by the treatment?

Which net water volumes are needed by the different consumers?

Which reserves or futures extensions have to be put into consideration?

## **The existing raw water analysis is not sufficient**

- **Change of water quality over the year (e. g. dry and rainy season)**
- **Insufficient ion balance**
- **Relevant substances in water not analyzed**

**→ An insufficient raw water analysis leads to a wrong design of the water treatment plant by the supplier**

# Example of a Raw Water Analysis

Parameter	RAW WATER	TREATED WATER
Alkalinity as CaCO <sub>3</sub> , mg/L	85.2	85.4
Aluminium Al, µg/L	7.39	10.6
Bromide Br mg/L	<0.05	<0.05
Cadmium Cd, µg/L	<0.1	<0.1
Calcium Ca, mg/L	20.6	23.3
Calcium Hardness as CaCO <sub>3</sub> , mg/L	37.4	36.4
Chloride, Cl mg/L	2.60	4.46
Chromium Cr, µg/L	<0.2	<0.1
Cobalt Co, µg/L	<0.2	<0.1
Conductivity µS/cm	142	148
Copper Cu, µg/L	12.4	8.223
Fluoride, F mg/L	0.44	0.18
Iron Fe, µg/L	1.06	<0.05
Lead Pb, µg/L	<1	<1
Magnesium Mg, mg/L	5.97	5.90
Manganese Mn, µg/L	<0.2	<0.2
Nickel Ni, µg/L	<0.5	<0.5
Nitrate NO <sub>3</sub> , mg/L	0.79	0.958
Nitrite NO <sub>2</sub> mg/L	<0.1	<0.1
pH	7.75	7.78
Phosphate PO <sub>4</sub> , mg/L	<0.2	<0.2
Potassium K, mg/L	6.94	7.15
Sodium Na, mg/L	5.41	5.68
Sulphate SO <sub>4</sub> , mg/L	3.10	2.33
TDS	92.3	96.2
Temperature, Celcius,	29.1	26.6
Total Hardness as CaCO <sub>3</sub> , mg/L	70.7	75.2
Turbidity NTU	5.77	0.43
Zinc Zn, µg/L	<0.2	<0.2

**Relevant parameters are missing, e. g.**

- Total organic carbon (TOC)
- Total suspended solids
- Silica
- Barium (in case of RO)
- Strontium (in case of RO)

**Fluctuations over the year are not to be seen**

- Range or max. values

# Raw Water Quality

## Two raw water qualities at one site

- Groundwater  
only in case of sufficient ground water level
- Surface water  
In case of not sufficient ground water level

→ Design of water treatment has to fit worst raw water quality

# Basic Considerations

What is the redundancy concept?

Which automation level is needed?

Which permits are relevant or have to be applied for?

Will it be allowed to discharge waste water?

What are the relevant discharge limits?

Are there restrictions in the usage of certain chemicals?

# Experiences with Chinese Suppliers

Standard raw water treatment solution without considering local conditions like raw water qualities

Water velocities too high

Necessary retention times for reaction too low

Plastic materials (piping, tanks, lamellas) not UV resistant

Equipment which is not available locally

Labelling in Chinese



# Experiences with Chinese Suppliers

Insufficient materials

Chinese workers not familiar with special requirements

Many black box systems

Chinese Standards

Operation manuals missing or not in English

No calibration of measuring equipment

# Corrosion after ~ 1 Year Operation



# Corrosion during Commission



# Laboratory after ~ 1 Year Operation



# Manuals after ~ 1 Year Operation




# Measurements



# Labelling



# Simple Raw Water Treatment Plant with PAC





# PAC Treatment in Comparison with $\text{FeCl}_3$

## PAC

- **pH ~ 7**  
**solubility increases if pH decreases or increases**
- **Light weighted flocs**  
**bad sedimentation**
- **Decarbonisation with pH ~ 10 not recommended because of precipitation of  $\text{Al}(\text{OH})_3$  in cooling tower basin (wet cooling)**

## $\text{FeCl}_3$

- **pH > 6**  
**low solubility**
- **Heavy weighted flocs**  
**good sedimentation**

# Flocculation



# Comparison of Water and Steam Quality Requirements for Drum Type Boiler




	Direct Conductivity μS/cm		Cation Conductivity μS/cm		Sodium μg/l		Silica μg/l	
	EPC	Int.	EPC	Int.	EPC	Int.	EPC	Int.
Demi water	< 0.4	< 0.2			-	< 0.5	< 20	< 5
Feed water			< 0.3	< 0.1			< 50	< 5
Superheated steam			< 0.3	< 0.1	< 10	< 5	< 20	< 5
Boiler water			< 60	< 30			< 450	< 200

# IP Turbine Rotor after ~ 1 Year Operation




**“The bitterness of poor quality remains long after the  
sweetness of low price is forgotten”**

**- Benjamin Franklin -**



**Take care from the early beginning until the end!**

# FGD Waste Water Treatment Plant Units 5 & 6 – 2 x 210 MW



## Removal of following components:

- Hg (Mercury)
- Cr (Chromium)
- Cd (Cadmium)
- Ni (Nickel)
- V (Vanadium)
- SO<sub>4</sub> (Sulphate)
- Solids

## No removal of Chlorides → soluble salts

Dewatered sludge has to be deposited in landfill classes II or III depending on composition.


### Requirements landfill class II:

- mineral drainage layer of 0,5 m

### Requirements landfill class III:

- Thicker and more complex geological barrier
- Leakage detection system
- Special monitoring

# Zero Liquid Discharge for humid regions Waste Water Evaporation plant




Further reduction of concentrated waste water discharge can be reached with a downstream centrifuge or pressure filter. Own consumption for 7.5 m<sup>3</sup>/h waste water is estimated to approximately 250 kWh/h, 900 kg/h steam (3bar) and 25 m<sup>3</sup>/h of cooling water.

# Clean gas discharge via cooling tower


## General situation

- Discharge of clean gas has to be permitted by local authority
- Coating Icosit-2406 by Sika is appropriate for cooling towers with discharge of clean gas, evaluation on technical execution should be done
- Discharge of clean gases via not operating cooling tower is not feasible






# Example for possible saving of water 2 x 520 MW Power Station in India




# Flocculation & Sedimentation System



# Example for possible saving of water 2 x 520 MW Power Station in India




# Example for possible saving of water 2 x 520 MW Power Station in India



**Efficiency of installed Reverse Osmosis Plant is 71 % and approx. 4 % under the standard design value**

**Normally, boilers in India are designed for 3 % make up (100 tons/hrs for 1000 MW). VGB conformed demi-water usage:**

- **Drum boiler: max. 2 %,**
- **Benson boiler max. 1.5 %**



# steag

Contact:

Dipl.-Ing. Matthias Schneider  
STEAG Energy Services GmbH

Ruettenscheider Str. 1-3

45128 Essen / Germany

Phone: +49 201 801-2859

Mobile: +49 171 566-9263

E-Mail: [matthias.schneider@steag.com](mailto:matthias.schneider@steag.com)