






Flexibility Requirement in Indian power system

01st December 2017

Indian Grid...Large Footprint



Indian Power System

- Peak Demand ~ 160 GW
- Energy Met ~ 3.5 BUs/day
 - Hydro Gen. ~ 712 MU/day (Max.)
 - Wind Gen. ~ 310 MU/day (Max.)
- Generating Stations ~ 900 Nos.
- Generating Units ~ 2200 Nos.
- > 7000 Sub-stations,
- > 3100 transformers
- 10 Nos. HVDC Bi-pole/BtB
- > 100 nos. 765 kV lines
- > 1300 nos. 400 kV lines,
- > 3200 nos. 220 kV lines
- 26 ISTS transmission licensees


Indian Power Market

- Licensed Traders - 43 Nos.
- Market Participants > 3000 Nos.
- Two Power Exchanges (PXs)
 - Indian Energy Exchange
 - Power Exchange of India Ltd.
- Open Access Volumes
 - Transactions ~ 45,000 Nos./yr.
 - Bilateral ~ 14,000 Nos.
 - Collective (PX) ~ 31,000 Nos.
- Energy ~ 100 BUs/yr.
 - Bilateral ~ 65 BUs
 - Collective (PX) ~ 35 BUs
- Short Term ~ 10 %


International Interconnections



Typical All India Load Pattern




Increasing trend of demand met




- Hourly demand met pattern

- Maximum, Minimum and Average Demand met pattern.




Hourly Variability of Demand



Increasing Flexibility Requirement



All India Total Gen. : Changing Pattern of Difference of Peak-Lean as a % of Peak

$$y = 5E-08x^2 - 0.0043x + 87.931$$
$$R^2 = 0.0905$$




- Peak demand increasing year after year
- Difference between daily peak and lean is showing an increasing trend
- Growth during peak hours is much more than lean hours
- Need for more flexible generation to counter this gap


Ramping in All India Demand



All India Thermal Generation




All India Hydro Generation




Solar Generation





Solar gen as % of total capacity




NPKUNTA SOLAR GENERATION VARIABILITY RAMP UP BLOCK



Flexibility index = $((\text{Max}-\text{Min})/\text{Max})$ over the years



All India Plant Load Factor (%) of Thermal Power Stations Coal and Lignite based





Ancillary Services

RRAS Providers:
48 Nos.

Capacity under RRAS:
51 GW

Maximum 'Up'
Regulation :
3746 MW

Maximum 'Down'
Regulation :
1946 MW



Lowest Variable Charge
~ Rs. 1.25 / Unit
(CGPL- WR)

Highest Variable Charge
~ Rs. 8.12 / Unit
(Anta LF- NR)

RRAS Dispatch :
48 Time-blocks / day
(Avg.)

Energy Dispatched:
Up – 6 MU / day
Down – 1 MU / day

Avg. Daily Number of
RRAS Instructions :
06 to 07 Nos.


Energy Dispatched:
Up – 6 MU / day
(0.2% of Energy met)

Energy Dispatched:
Down – 1 MU / day
(0.03% of Energy met)

Pumped Storage Plants in India

S. No.	Name of Project / State	Installed Capacity		Pumping Mode Operation	Reasons for not working in Pumping mode
		No. of units x MW	Total (MW)		
1	Kadana St. I&II Gujarat	2x60+2x60	240	Not working	Due to vibration problem
2	Nagarjuna Sagar Andhra Pradesh	7x100.80	705.60	Not working	Tail pool dam under construction
3	Kadamparai Tamil Nadu	4x100	400	Working	-
4	Panchet Hill - DVC	1x40	40	Not working	Tail pool dam not constructed
5	Bhira Maharashtra	1x150	150	Working	-
6	Srisaillam LBPH Andhra Pradesh	6x150	900	Working	-
7	Sardar Sarovar Gujarat	6x200	1200	Not working	Tail pool dam not constructed
8	Purlia PSS West Bengal	4x225	900	Working	-
9	Ghatgar Maharashtra	2x125	250	Working	-
		Total	4785.60		

Pumped Storage



Provisions Regarding Ramping

- **Provisions in the Indian Electricity Grid Code (IEGC):**
 - Operating Code (Section 5.2):
 - System Security Aspects - Ramping of
 - All thermal units greater than 200 MW.
 - All Hydro units greater than 10 MW
 - Sudden change in generation / load by the utilities of more than 100 MW without prior intimation to and consent of the RLDC.
 - Scheduling and Despatch Code (Section 6.4)
 - Generators to declare rate of ramping up / ramping down in a 15 minute block.
 - Acceptable ramping rate – 200 MW/Hour (in NER 50 MW/Hour)
- **CEA Standard Technical Features of Super-Critical Units**
 - Ramp rate: + 3% per minute (above 30% loading)
 - Technical minimum load of super critical units – 40%
 - Two shift operation mandated

Technical minimum

- **CERC grid code fourth amendment regulations 2016**
 - Technical Minimum - 55%
 - Implementation is notified by CERC
- **Beneficiaries (DISCOMs) are directed to compensate for the Heat rate degradation**


S. No.	Unit loading as a percentage % of installed capacity of the unit	Increase in SHR for supercritical units (%)	Increase in SHR for sub – critical units (%)
1	85-100	Nil	Nil
2	75-84.99	1.25	2.25
3	65 -74.99	2	4
4	55-64.99	3	6

Increasing granularity of Despatch Interval

- 5-minutes scheduling:
 - ❑ Reduced the steep ramps
 - ❑ Eliminates sharp discrete changes
 - ❑ Reduced frequency fluctuations
 - ❑ Facilitates better load management
 - ❑ Facilitates integration of renewables

Flexible Generation

- **Hydro**
 - Plan and implement more pumped storage
 - Operational norms to incentivize flexibility
- **Thermal**
 - Grid Code clauses on flexibility (ramp rate, minimum)
 - Incentives for flexible generation
 - Two-shift operation of thermal plants
 - Primary, Secondary and Tertiary Controls
- **Renewables**
 - Low Voltage Ride Through (LVRT)
 - Draft CEA standards notified



Flexible Transmission

- **HVDCs in India**
 - 4 back to back HVDCs
 - 6 bipole HVDC links
 - 1 MTDC
 - 1 more planned

- **CEA Transmission Planning Criterion (Section 18)**
 - More than 2000 MW over long distance more than 700 km.
 - Corridors of AC lines carrying heavy power flows (total more than 5000 MW)

Signs of Inflexibility

- Difficulty in balancing demand and supply
 - Frequency excursions
- Renewable curtailment
 - Inability to balance
- Area Balance Violations (Deviations)
- Electricity Markets
 - Price volatility


Source: Cochran, J. et al. (2012), "Flexibility in 21st Century Power Systems, A 21st Century Power Partnership Report". Golden, CO: National Renewable Energy Laboratory.

<http://www.nrel.gov/docs/fy14osti/61721.pdf>

Way Forward

- **Power systems are already flexible, designed to accommodate variable and uncertain load.**
 - New actors RE, distributed generation, storage etc. to be accommodated
- **Need for 'Flexible' Systems**
 - **Flexible Generation**
 - **Flexible Transmission** – FACTs, HVDC
 - **Flexible Distribution** – Price responsive demand
 - **Flexible Markets** -
 - More Frequent market operation, Ancillary services, Demand response
- **Policy / Regulatory Framework for Flexibility**
 - Measuring Flexibility
 - Metrics for performance
 - Incentivizing and paying for flexibility
 - Policy support to anticipate flexibility needs and support system flexibility
 - Flexibility considerations can be integrated into the design of procurement policies

Flexibility Requirement in Indian Power System



https://posoco.in/download/flexibility_requirement_in_indian_power_system/?wpdmdl=711



Power System Operation Corporation Limited

New Delhi

January 2016

Thank You