


NTPC R&R Colony,
Darlipali



NTPC Bhadla



NTPC Kudgi




NTPC Koldam

"NTPC EXPERIENCE – FLEXIBLE OPERATIONS"



NTPC Simhadri



NTPC Rojmal

India's Commitment in COP26

- India will bring its non-fossil energy capacity to 500 GW by 2030
- India will bring its economy's carbon intensity down to 45 per cent by 2030
- India will fulfil 50 per cent of its energy requirement through renewable energy by 2030
- Achieving Net zero Emission by 2070


India achieves the committed NDC (Nationally determined Contribution) target of 40% of its installed electricity capacity from non fossil fuel

75
Azadi Ka
Amrit Mahotsav

mnreindia MNREMinistry mnre.gov.in


All India capacity of Today vs Projected upto 2029-30

As on 31.10.2022



Total Capacity: 408714 MW


Projected in 2029-30



Total Capacity: 817254 MW

CEA –Recommendation for Flexible Operation of Thermal Plants

Generation trends on a given sunny day



Contribution from different fuel sources in meeting demand-2021-22


- Coal Units should have the capability of 1% ramping to take care of this integration
- Coal units are to be flexed upto 40% MTL. Plants <150 MW to be retired or subjected to 2 shift operation.
- Provision of 55% technical minimum load of thermal units.

Flexibilization Types

What is Cyclic operation ?

- Start up/Shut down (Hot/Warm/Cold)
- On load cycling (LL1,LL2,LL3)
- Higher ramp rate
- High frequency load variations (RGMO/AGC)

- Thermal fatigue combined with creep is the main cause of damage.
- Cyclic load variations within SH/RH temp. control range may be tolerable
- Start/stops are the severest in terms of life consumption



Load cycling

LL1—lowest load at which design SH/RH temperatures can be maintained

LL2—current "advertised" low load

LL3—lowest load at which the unit can remain online


Flexibility Studies with International Associates

Associates	Plant	Study period	Scope
IGEF/VGB, Germany	Dadri Unit 6 (500MW)	Jan- Aug 2018	MTL (40%) & 3% Ramping
GE, USA	Talcher-K Unit 1 (500 MW)	April-Aug 2018	MTL (40%)
USAID/BHEL	Mauda Unit 2 (500 MW)	April-Aug 2019	MTL (40%)
J-Coal/TEPCO, Japan	Vindhyachal Unit 11 (500 MW) Mauda Unit 3,4	March–July 2019	Minimum loading (55%) with 3% ramping. Efficiency at different part load condition
EPRI, USA	Solapur, Gadarwara, Simhadri, Bongaigaon, Farakka and Unchahar	Mar'20 onwards	Identifying gap in intended O&M practices to be followed in view of flexible operation of fleet

Challenges faced at min loading operation




Combustion and Flame Stability



Increased Boiler Tube Failures




Ash Deposition at Low Loads



Tuning - Process Control loops



Variations in coal quality



Thermal Fatigue - Failure of Thick walled components


Common Observations of the Pilot Studies

In all the Studies, field tests were conducted in strictly controlled environment with good coal quality in presence of functional experts.


Minimum Technical Load of 40% for 2-4 hrs with following Technical issues

- Excessive fluctuations in Steam temperatures
- High Drum level swings during ramping
- Flame disturbance during ramping and at MTL
- Occasional furnace pressurisation
- Stalling of PA fans at low load
- Low boiler flue gas exit temperature, leading to acid corrosion
- With 3% ramp commands, actual ramp rate achieved in full load range was only 1.3-1.4% due to manual milling system operation.

Typical MS and HRH steam temp fluctuation ~ 20-30 Deg C



RH metal temp crossing the excursion limit




Issues encountered during Pilot Test run at MTL of 40%

Flame scanners at 100% vs 40% load: Safe operation of Boiler?


Unit-2 flame scanners at 500MW load

Unit #2 : Date: 29.05.2019 Time: 12:48,
Mills in service : B,C,D,E,F & G



Mouda & Dadri Experience


Unit-2 flame scanners at 200MW load



Date: 29.05.19 Time: 16:28:30 Hrs,
Mills: C, D, E in service (without oil support)

- Interventions Required:**
- a) Mill Scheduler
 - b) Online Coal flow monitoring system
 - c) Upgradation of Flame scanner
 - d) Burner replacements
 - e) Smaller size Mill installation
 - f) Consistency in Coal quality


Drum level fluctuation



Interventions Required:

- TDBFP Recirculation Valves to be replaced with modulating type.
- Loop Tuning upto 40% MTL

Steaming in Economiser and flow accelerated corrosion




FW Temp at eco i/l: Dipping down to 220°C at 55% from 254°C at 100% Load


Interventions Required:

- a) Additional HP Heater
- b) Loop Tuning w.r.t MS press & following Modified sliding press.

Low primary air flow can lead to stalling




Flexibilization Implementation



Reducing Minimum Load

Common Turn-down Challenges:

- Controlling steam temperatures.
- Flame Stability
- Feedwater control
- Environmental Controls
- Excessive cooling of steam turbine due to control valve throttling
- FD and ID fan vibrations
- Damage to back end of LP turbine




Fast Load Ramping

Limitations

- Temperature control
- Pressure Control
- Level Control

Common Solution

- *Control loop tuning*
- *Improved coordination of boiler and turbine masters*



Dadri Unit#6 -40% Minimum loading operation-

- Predictive Main steam Temperature Control
- Reheat Steam Temp control
- Installation of Modulating Recirculation valves in BFPs
- Automation in Milling system
- Flue Gas temp control
- Single drive operation- Automated start/ stop of ID/FD/PA fans
- Condition monitoring system- Boiler Fatigue Monitoring System and Equivalent Operating Hours

Conclusions

- **Coal based units are to be flexed** – Min tech load, High Ramp rate, Frequent start up
- **Cost associated with flexibilization-** Part load degradation, start up cost, life consumption cost due to flexing and same is to be adequately compensated through regulatory mechanism.
- **Plan and prepare** - Competency development, Advance process control, new Technology intervention to minimize life consumption.
- **Phasing down rather Phasing out-** At least for another two to three decades coal units will stay here for sure.

Thank You